



**DAMODAR VALLEY
CORPORATION**
(Under the Ministry of Power, GOI)

**“EXPERIENCE IN FLEXIBILIZATION”
BY
TEAM DVC**

Date: 24.11.2022

Venue: The Park, New Delhi

DAMODAR VALLEY CORPORATION (DVC)

- **First Multipurpose River Valley Project of independent India.**
- **Established on July 7, 1948 by an Act of the Constituent Assembly of India (Act No. XIV of 1948).**
- **Modelled on the Tennessee Valley Authority (TVA) of the USA.**
- **Central Government of India and the State Governments of West Bengal and Bihar participate jointly for the purpose of building the DVC**

DVC PROJECTS OVERVIEW

Thermal Power Plant:

1. Bokaro TPS (1 X 500 MW)
2. Chandrapura TPS (2 X 250 MW)
3. Durgapur Steel TPS (2 X 500 MW)
4. Koderma TPS (2 X 500 MW)
5. Meija TPS (4 X 210 MW + 2 X 250 MW +2 X 500 MW)
6. Raghunathpur TPS (2 X 600 MW)

Hydel Power Plant:

1. Maithon HPS (2X20 MW + 1X23.2 MW)
2. Panchet HPS (2X40 MW)
3. Tilaiya HPS (2X2 MW)

FLEXIBILIZATION

- **Flexibility of a Power System: Generation or Demand can be increased or reduced over a timescale ranging from a few minutes to several hours.**
- **Most measures for flexibility: Low minimum Load operation.**

POSSIBLE CHALLENGES

- **Higher Boiler Tube Wall Metal temperatures.**
- **Flame disturbance during ramping up/ramping down.**
- **Unstable Furnace pressure,**
- **Stalling of PA Fans at lower load regime.**
- **Unstable feed water control with Two TDBFPs at low load.**
- **Low Flue gas temperature at APH.**
- **Due to corrosion boiler drains may also burst leading to unsafe situation.**
- **Heat rates typically degrade at partial load due to lower steam parameter (Pr. and temp) and Low Feed water temp at ECO inlet.**

POSSIBLE CHALLENGES

- **Excess air can cause high dry flue gas loss.**
- **Difficulties in maintaining Optimum steam chemistry.**
- **Low Furnace to Windbox dP and subsequent Boiler tube failure in the burner zone.**
- **Fast & Frequent thermal cycling of components lead to fatigue, creep .**
- **Failures of boiler tubes caused by cyclic fatigue, corrosion fatigue and pitting .**
- **Cracking in dissimilar metal welds, headers and valves, and other thick-walled components due to rapid changes in steam temperature.**
- **LPT last stage blade is prone to failure due to handling of Wet steam.**

PRE-CHECKS REQUIRED

- **All auto loops should be available and fine tuning of CMC must be carried out to minimize the deviation of parameters**
- **Attemperator system must give fast response to the changing system demand.**
- **Optimise minimum coal loading in a mill by fine tuning primary air flow vs. coal flow curve to avoid lean air mixture and possible flame failure tripping.**
- **Clean air flow test/Dirty air flow test at regular interval to evaluate partially plugged coal pipes and burners**
- **SADC damper operation should be checked and correct feedback must be made available.**

PRE-CHECKS REQUIRED

- **Wall blowers and LRSB operation scheduling should be done**
- **Water chemistry should be available in DCS.**
- **SCAPH operation to be made through to contain flue gas temperature less than acid dew points**
- **BTLD should be in healthy condition and in service.**
- **All TSI feedback should be available in service and in healthy condition.**
- **MDBFP should be ready and in stand by condition.**
- **Flame scanners were thoroughly cleaned and calibrated for flame stability.**

FLEXIBILITY TEST

- **DSTPS Unit 2, DVC was selected by the Central Electricity Authority (CEA) to investigate the flexibilization potential of thermal capacity in the Eastern Region.**
- **The activities at DSTPS plant were executed jointly with experts from IGEF, Siemens Energy (Germany), Siemens India and VGBe.**
- **Flexibility tests were conducted at DSTPS with the aim of achieving 40% minimum technical load and ramp rate of atleast 1.5% per minute.**
- **The test runs were executed from 28 to 31 March 2022 by the Team of DVC, IGEF, Siemens and VGBe experts.**
- **The tests were planned and carried out in close co-operation with CEA and POSOCO.**

MAIN DESIGN DATA OF DSTPS

- **Capacity : 2 x 500 MW**
- **Boiler : Single drum Boiler, Directly fired by pulverized coal, Tilting tangential firing, Sub-critical , Manufactured by BHEL.**
- **Turbine : Single-flow HP turbine, double-flow IP and LP turbines ,Manufactured by BHEL – KWU design**
- **Cooling : Closed cycle with Natural draft cooling tower**

DATE OF TEST PERFORMED

- **28 March'22 : Minimum Load Test [200 MW (or less)]**
- **29 March'22 : Minimum Load Test [200 MW (or less)]**
- **30 March'22 : Load Ramp Test between 200 and 500 MW**
- **31 March'22 : Load Ramp Test between 200 and 500 MW**

ACHIEVED

- **During the minimum load tests, the plant was operated for two hours at stable minimum load of 160 MW (32% load).**
- **The highest ramp rate achieved in upwards direction was 12 MW/min and in downwards direction 16 MW/min.**

GLIMPSE




GLIMPSE



GLIMPSE



GLIMPSE



GLIMPSE



STEPS TOWARDS MINIMUM LOAD

- **Unit was running with 505 MW in CMC mode with B,C,D,F,G,H coal mill in service without oil support.**
- **Load set point reduced in steps of 10 MW from 505 MW.**
- **At 470 MW: Feeder H taken out,**
- **At 440 MW: Feeder G taken out,**
- **At 370 MW: Coal Feeder F taken out of service keeping consecutive mill operation for better flame stability.**
- **Load was reduced 290 MW gradually keeping lower mills (B, C, D) at minimum coal flow of 45 TPH and was kept for 2 hrs. for stability.**

STEPS TOWARDS MINIMUM LOAD

- **At 270 MW - as a precautionary measure, TDBFP ACV put into service from CRH, as IP extraction pressure to both TDBFP becomes low at lower load, due to which disturbance in drum level occurs.**
- **After stability in TDBFP, one TDBFP was unloaded and keep at 3500 RPM then load was further reduced to 250 MW.**
- **Oxygen set point was slowly raised to 5.5 % and waiting for 15 minutes to attain furnace stability.**
- **SCAPH was charged to maintain FG, PA & SA temperature.**

STEPS TOWARDS MINIMUM LOAD

- **Load further reduced in CMC to load 220 MW: One FD Fan was taken out of service and keeping base mills minimum coal flow setpoint to 40 TPH.**
- **Turbine throttle pressure was reduced manually and machine taken into pressure control mode (limit of minimum load set point of CMC : 200 MW).**
- **Burner Tilt was adjusted as per requirement to raise RH temperature observing flame stability.**
- **Manual Damper (SADC) i.e. AA was reduced to 25 % at all four corners to keep wind box DP above 40 mmwcl (BHEL design curve).**
- **Oxygen set point was further raised to 6.8 % to maintain Wind box dP.**

STEPS TOWARDS MINIMUM LOAD

- **Slowly Load was reduced to 155 MW.**
- **At this load, Coal Flow 92 TPH, Coal Ratio 0.593 kg/kwh, MS Pressure 90 ksc, Oxygen Set point 6.8 %, Wind Box dP 20 mmwcl, MS/HRH temp 531/498 Deg C.**
- **After Stability, achieved 160 MW minimum load without oil support on 30.03.2022.**

OBSERVATIONS DURING TEST

AT 55%:

- **No such issue at 55% load.**
- **In transient load condition, drum level fluctuation due to opening of BFP recirculation valve.**
- **Higher APC due to marginal condition for 2 CEP & 2 CW running.**
- **Load increase will take longer time if one CW pump is taken out from service.**
- **Reduction of operating coal mill takes higher time at higher ramp and quantum.**
- **Frequent load cycles increases fatigue loading of component and may causing Boiler tube leakage in attachment weld failure.**

OBSERVATIONS DURING TEST


At 40%:

- **Flame instability.**
- **Low wind box pressure hence chance of overheating in Water wall.**
- **Less Reliability with single FD Fan, BFP, and CEP as any tripping may cause Unit tripping.**
- **Any tripping of coal mill @ 30% Load, possibility may increase of malfunctioning of control loop including Drum Level .**
- **TDBFP steam source from CRH: at low load it works good but at higher load with higher CRH pressure, control by TDBFP Aux control valve is difficult.**
- **Proper tuning of control system required especially SH temp, Drum level.**

OBSERVATIONS DURING TEST


Ramp rate:

- **Up to 1% RAMP rate, no much problem at 55% but sudden change to higher load difficult as number of coal mill to be increased in service.**
- **At 40%, due to less margin, 2% ramp rate is difficult . Also, higher ramp rate can not be achieved as less number of drives are running and starting of required equipment takes time.**



Throughout the trial, Coal Ratio was in the range of 0.55 kg/kWh to 0.60 kg/kWh

Dynamic 8 Point Trend



30Mar2022 12:10:00

.Out.Sample	Pending...	ACTUAL LOAD	164.9787 MW
Drum Pressure Actual	91.6283 Kg/cm ²	Drum Level Actual(Average)	-32.1435 mmWC
.Out.Sample	Pending...	.Out.Sample	Pending...
.Out.Sample	Pending...	.Out.Sample	Pending...

MS Lines Drains	SH STEAM VENTS	CRH/HRH SIM							
				Last	Main	2DrumLevelActual	Pop		
				Close All PopUps		Drum Level Actual(Average)			
						"TRENDS\DT8Pt.mn"			

Clear Point
Ack Point


Throughout the trial drum level fluctuated continuously from +90 mmWC to -257 mmWC

Dynamic 8 Point Trend

Actual_MV3.Out.Sample

ACTUAL LOAD

200.7966 MW



HRH Temp 483 deg

10:30

12:30

14:30

16:30

18:30

20:30

22:30

00:30

30Mar2022

30Mar2022

30Mar2022

30Mar2022

30Mar2022

30Mar2022

30Mar2022

31Mar2022

30Mar2022 13:00:00

2HRH_OLTLLeft.Out.Sample	483.3087 °C
Drum Pressure Actual	103.0080 Kg/cm²
.Out.Sample	Pending...
.Out.Sample	Pending...

ACTUAL LOAD	200.7966 MW
.Out.Sample	Pending...
.Out.Sample	Pending...
.Out.Sample	Pending...


MS Lines Drains	SH STEAM VENTS	CRH/HRH STM			
-----------------	----------------	-------------	--	--	--

Last	Main	2DrumPrActual
Close All PopUps		Drum Pressure Actual
"TRENDS\DT8Pt.mn"		

Pop

At Load 200 MW: HRH Temp Dropped to 483°C

Dynamic 8 Point Trend



30Mar2022 12:10:00	
2HRH_OLTL .Out.Sample	498.7613 °C
Drum Pressure Actual	91.6283 Kg/cm ²
.Out.Sample	Pending...
.Out.Sample	Pending...
ACTUAL LOAD	154.9787 MW
.Out.Sample	Pending...
.Out.Sample	Pending...
.Out.Sample	Pending...

MS Lines Drains	SH STEAM VENTS	CRH/HRH SIM	Last	Main	2DrumPrActual	Pop
Close All PopUps				Drum Pressure Actual		
				TRENDSDT8Pt.mn*		

At 154 MW Load: HRH Temperature Increased to 498 °C

Dynamic 8 Point Trend



.Out.Sample	Pending...
Drum Pressure Actual	91.6283 Kg/cm ²
.Out.Sample	Pending...
.Out.Sample	Pending...

ACTUAL LOAD	154.9767 MW
WindBoxToFurDPT2	23.6100 mmWC
.Out.Sample	Pending...
.Out.Sample	Pending...

FIRSTOUT

Last Main 2HBK15CP101_XQ01

Close All PopUps

WindBoxToFurDPT2

"TRENDS\DT8Pt.mn"


Pop

Clear Point

Ack Point

Wind box DP maintained very low. At 154 MW it dropped to 23 mmWC

Dynamic 8 Point Trend



29Mar2022 15:45:00	
2O2_SEL.Out.Sample	6.9423%
2HBK10CP101_XQ01.Out.Sample	23.9898mmWC
.Out.Sample	Pending...
.Out.Sample	Pending...

2TotalAirFlow.Out.Sample	839.2698 T/Hr
2load_actual_MV3.Out.Sample	188.7378 MW
.Out.Sample	Pending...
.Out.Sample	Pending...

POST TEST OBSERVATIONS

- Boiler Tube Leakage observed at 18:00 hrs. on 02.04.2022
- Affected area : Front Water Wall Tube attached to seal box of Wall Blower no. 4 at 52mtr. And LHS at 55 mtr. Elevation at Inspection door (Attachment welding joint failure.)



REQUIREMENT

- **Automatic Mill Operation (Mill Scheduler) .**
- **Better tuning of MS/RH Temperature/burner tilting and Drum level Control loop .**
- **Automated Start of Fans and Pumps .**
- **Integrated Start up automation.**
- **Online coal flow measurement system ,**
- **Conversion of Operation for BFP RC valve from ON-OFF to Modulating type.**



धन्यवाद

