

# Indian Scenario of Super Critical Power Plants Issues and Challenges

T K Seal - GM(COS-OPN)  
D.Bose -AGM(COS-Commng)

# Supercritical Units -Indian scenario

## *Contents*


1. Power scenario in India
2. What is Supercritical Technology
3. Benefits of Supercritical Technology
4. Supercritical Units in India
5. Profile of NTPC
6. Sipat & Barh -Supercritical Units of NTPC
7. Chemistry Regime
8. Boiler Control- Sliding Pressure Operation
9. Issues & Challenges
10. Sipat - Performance at a Glance
11. Q & A

# Indian Power Mix


<b>Installed Capacity( MW)*</b>	
<b>Coal</b>	<b>167208</b>
<b>Gas</b>	<b>23062</b>
<b>Diesel</b>	<b>994</b>
<b>Nuclear</b>	<b>5780</b>
<b>Hydro</b>	<b>41997</b>
<b>Renewable</b>	<b>35777</b>
<b>Total</b>	<b>274818</b>

\*Excluding captive generation capacity (40726 MW)

### Installed Capacity (MW)



# Share of supercritical units (MW)




## WHY SUPER CRITICAL TECHNOLOGY

- ✓ Reduced emission for each Kwh of electricity generated
  - ✓ *1% rise in efficiency reduces the CO2 emission by 2-3%*
  - ✓ The Most Economical way to enhance efficiency
  - ✓ Fuel cost saving : Economical
  - ✓ Operating Flexibility
  - ✓ Reduced the Boiler size / MW
  - ✓ Reduced Start-Up Time
-



# Supercritical

- Critical is a thermodynamic expression describing the state of a fluid beyond which there is no clear distinction between the liquid and gaseous phase.
- The critical pressure & temperature for water are
  - Pressure-225.56 kg/cm<sup>2</sup>
  - Temperature -374.15°C
- A boiler operating at a pressure above critical point is called 'supercritical boiler'
- A point where boiling water and dry saturated line meet so that associated latent heat is zero

# SUPER CRITICAL BOILER CYCLE WITH SH, RH & Regeneration








**Boiling process in Tubular Geometries**

# Sub Critical - Ultra Super Critical March Towards Higher Efficiency With Application of Higher Grades of Materials



# Efficiency Comparison

CAPACITY	500 MW	660 MW	800 MW
BOILER EFFICIENCY (%)	85.61	86.27	86.33
TURBINE HEAT RATE (kCal/kWh)	1944.4	1904	1826
PLANT HEAT RATE (kCal/kWh)	2271.23	2207.02	2115.13
PLANT EFFICIENCY (%)	33.78	38.96	40.68

## Sipat 660 MW

Main steam : 256 ksc, 540°C  
Reheat steam : 48.3 ksc, 568°C

## 800 MW


Main steam : 258 ksc, 568°C  
Reheat steam : 54.23 ksc, 596°C

## Barh 660 MW

Main steam : 253.4 ksc, 568°C  
Reheat steam : 51.7 ksc, 596°C

# INCREASE IN PLANT EFFICIENCY by SUPER CRITICAL PARAMETERS

Efficiency Increase



# Existing supercritical units

<b>State</b>	<b>Station</b>	<b>Capacity</b>
Bihar	Barh (NTPC) #4	660
	Barh (NTPC) #5	660
Chattisgarh	Sipat (NTPC) #1	660
	Sipat (NTPC) #2	660
	Sipat (NTPC) #3	660
Maharashtra	Koradi #8	660
	Tirora TPP(Phase 1) #1	660
	Tirora TPP(Phase 1) #2	660
	Tirora TPP(Phase2) #1	660
	Tirora TPP(Phase2) #2	660
	Tirora TPP(Phase2) # 3	660
Andhra Pradesh	Painampuram TPP #1	660
Gujrat	Mundra UMPP #3	800
	Mundra UMPP#4	800
	Mundra UMPP#5	800

# Existing supercritical units

State	Station	Capacity	Date of Commissioning
Punjab	Rajpura TPP#1	700	24.01.2014
	Rajpura TPP#2	700	06.07.2014
	Talwandi Sabo TPP #1	660	17.06.2014
Madhya Pradesh	Sasan UMPP #1	660	21.05.2014
	Sasan UMPP #4	660	25.03.2014
	Sasan UMPP #5	660	24.08.2014
	Sasan UMPP #6	660	19.03.2015
	Nigri TPP #1	660	29.08.2014
	Nigri TPP #1	660	17.02.2015
Rajasthan	Kawai TPP #1	660	28.05.2013
	Kawai TPP #2	660	24.12.2013
Haryana	Jajjar TPP #1	660	11.04.2012
	Jajjar TPP #2	660	

# ***NTPC - THE LEADER IN POWER SECTOR***

- NTPC's total installed capacity is 45,548 MW in Country's total installed capacity of 274817.94 MW.
- NTPC's share in country's total power generation is 23.81%
- During 11<sup>th</sup> plan 9,610 MW was added, exceeding the target of 9,220 MW
- Out of 24 ( 18 NTPC + 6 JV's) nos. coal based plants, 6 stations achieved PLF of more than 85 %
- NTPC plans to add 14,038 MW capacity during 12<sup>th</sup> plan period (of which 8445 MW has been already added till August 2015) .
- Projects totaling 23004 MW ( 21 nos) are under construction
- NTPC has made it's presence in Renewable by commissioning 8 nos Solar PV plants with total capacity of 110 MW.
- NTPC has also made forays into hydel generation,(recently 4x200 MW Koldam has started it's commercial operation), coal mining, power distribution & trading, solar energy and entered into JV's with SAIL & other state power utilities


# NTPC Projects with Super Critical Boilers

- ▶ **Commissioned Units** ( 3300 MW)
- ▶ Sipat (3x660 MW)
- ▶ Barh (2x 660 MW)
- ▶ **Under Commissioning** ( 6640 MW)
- ▶ Kudgi (3x800 MW)
- ▶ Lara (2x800 MW)
- ▶ Solapur (2x 660 MW)
- ▶ Mouda -II (2X660MW)



# NTPC Projects with Super Critical Boilers

- ▶ Upcoming Projects - under different phase of construction ( 9520 MW)
- ▶ Meja (2x660 MW)
- ▶ Khargone (2x 660 MW)
- ▶ North Karanpura ( 3x660 MW)
- ▶ Tanda II (2x 660 MW)
- ▶ Gadarwara (2x800 MW)
- ▶ Barh I (3x 660 MW)





02.06.2012 22:31

# Super critical units -NTPC Experience

**Sipat** : Boiler package supplier – Doosan Heavy Industries, South Korea  
: Turbine package supplier – Power Machines, Russia

## **Sipat 660 MW Boiler :**

- Once through supercritical, Two pass, Balanced draft, Out door
- Furnace width – 18816 mm, depth – 18144 mm, volume – 21462 m<sup>3</sup>
- Super Heater: Multi stage with panel, platen, pendant section
- Reheater: Multi stage type (LTRH & FINAL RH)
- Steam output parameters: at BMCR
  - ✓ Main steam : 256 ksc, 540<sup>0</sup>C, 2225 T/hr
  - ✓ Reheat steam: 48.3 ksc, 568<sup>0</sup>C, 1742 T/hr
- Design coal flow : 438 T/hr

# Super critical units -NTPC Experience

## **BOILER AUXILIARIES :**

### 1. Fans

ID Fan : Supplier : FlaktWoods, Sweeden  
Type : PFSU – 450 – 300 – 08

FD Fan : Supplier : FlaktWoods, Sweeden  
Type : PFSU – 280 – 112 – 04

PA Fan : Supplier : FlaktWoods, Sweeden  
Type : PFTU – 200 – 100 – 02

### 2. Air Preheaters

SAPH : Supplier : Doosan  
Type : 31.5 – VI – 1900

PAPH : Supplier : Doosan  
Type : 26.0 – VI – 1800

### 3. Mills

Vertical Bowl Mill 10 nos. – XHPS 1103

### 4. Coal Feeder

Gravimetric feeder 10 nos. – 36 inch

### 5. Boiler Recirculation Pump (BRP)

Make : Hayward Taylor, England  
Type : Wet stator, Glandless, Single section sing discharge  
pump

### 6. Oil elevations : 5 nos. (AB, CD, EF, GH & JK)

# Super critical units -NTPC Experience

Sipat 660 MW Turbine :

- Turbine Model: K-660-247 (LMZ, Russia)
- HP Turbine
  - ✓ 1 no. HP turbine, 17 stages
  - ✓ HP turbine has nozzle governing system
  - ✓ 2 nos. HP stop valves, 4 nos. HP control valves
  - ✓ 1 impulse stage + 16 reaction stages
- IP Turbine
  - ✓ 1 no. IP turbine, 11X2 stages
  - ✓ IP turbine has throttle governing system
  - ✓ 2 nos. IP stop valves, 4nos. IP control valves
  - ✓ 22 nos. impulse stages
- LP Turbine
  - ✓ 2 nos. LP turbines, (5X2 + 5X2) stages
  - ✓ 20 nos. impulse stages
- Number of journal bearing for turbine - 8, Number of journal bearings for generator - 4.
- 2 nos. MDBFP (30% each) & 2 nos. TDBFP (50% each)
- Steam turbine parameters
  - ✓ Before HPSV : 247 ksc, 5370C, 2023 T/hr
  - ✓ Before IPSV : 43 ksc, 5650C, 1681 T/hr
- Number of HP heaters : 6
- Number of LP heater : 4

# Super critical units -NTPC Experience

## SIPAT PROJECT KEY MILE STONES

	<i>UNIT # 1</i>	<i>UNIT # 2</i>	<i>UNIT # 3</i>
<b>Boiler Hydro Test</b>	<b>06.01.2007</b>	<b>27.07.2007</b>	<b>14.02.2009</b>
<b>Boiler Chemical Cleaning</b>	<b>03.09.2010</b>	<b>08.06.2011</b>	<b>26.01.2012</b>
<b>Boiler Lightup</b>	<b>26.10.2010</b>	<b>23.12.2011</b>	<b>26.08.2011</b>
<b>Steam Blowing</b>	<b>13.01.2011</b>	<b>13.08.2011</b>	<b>19.02.2012</b>
<b>Synchronization</b>	<b>18.02.2011</b>	<b>02.12.2011</b>	<b>01.04.2012</b>
<b>Full Load</b>	<b>28.06.2011</b>	<b>24.12.2011</b>	<b>02.06.2012</b>
<b><i>Commercial Operation</i></b>	<b><i>01.10.2011</i></b>	<b><i>25.05.2012</i></b>	<b><i>01.08.2012</i></b>

Super critical units -NTPC Experience

***STRINGENT CHEMISTRY REGIME***




# KEY FEATURE- OXYGENATED TREATMENT

- ▶ PROVIDES LONG TERM PROTECTION OF PRE BOILER SYSTEM BY FORMING HAMETITE LAYER.
- ▶ CPU OPERATING PERIOD WILL BE MORE DUE TO LOW CONDENSATE AMMONIA CONTENT
- ▶ IRON TRANSPORT WILL BE REDUCED BY 90%
- ▶ LESS GENERATION OF CRUD
- ▶ REDUCTION IN CHEMICAL CLEANING FREQUENCY
- ▶ REDUCTION IN OUTAGE TIME AND FASTER START UP
- ▶ FAC WILL BE MINIMIZED

ALL THESE LEAD TO VERY LESS BTF

# SCHEMATIC OF OXIDE GROWTH AND MORPHOLOGY UNDER OXIDISING AVT AND OT



# FEED WATER PARAMETERS

S.NO	Parameter	Units	Normal Operation		During Start up
			Alkaline water Treatment	Oxygenated Treatment	
1	<b>PH</b>		Min 9.0	<b>8-8.5</b>	Min 9.0
2	Cation Conductivity, $\mu\text{s}/\text{cm}$	$\mu\text{s}/\text{cm}$	Max 0.2	<0.15	Max 0.5
3	<b>Dissolved Oxygen</b>	<b>ppb</b>	< 5	<b>30-150</b>	<b>Max 100</b>
4	Iron	ppb	< 2	< 2	< 20
5	Sodium	ppb	< 2	< 2	< 10
6	Silica	ppb	<10	< 10	< 30
7	Turbidity	NTU	<2	< 2	<5

# OXYGENATED TREATMENT SYSTEM AT SIPAT - OXYGEN DOSING

- ▶ Dosing is being carried out in CPU outlet and Deaerator outlet
- ▶ The cycle oxygen is controlled by flow control valve having a automatic controller.
- ▶ The injection control is automatically adjusted by Feed water flow and residual dissolved oxygen and set point.
- ▶ DO should be in the range of  $< 20$  ppb in condensate.

# STEAM WATER ANALYSIS SYSTEM (SWAS)

FOLLOWING IS THE PROCESS MONITORING FOR CHEMICAL CONTROL OF STEAM AND WATER

S.NO	SYSTEM	TYPE OF MEASUREMENT
1	MAKE UP DM WATER	SP.COND., CATION CONDUCTIVITY (ACC)
2	CEP DISCHARGE	pH, ACC, Na, DO, SP.COND.,
3	CONDENSATE POLISHER O/L	pH, ACC, Na, SILICA, SP.COND.,
4	DEAERATOR OUTLET	DO
5	FEED WATER AT ECONOMIZER INLET	pH, ACC, COND.,HYDRAZINE,SILICA, TURBIDITY

# STEAM WATER ANALYSIS SYSTEM (SWAS)

FOLLOWING IS THE PROCESS MONITORING FOR CHEMICAL CONTROL OF STEAM AND WATER

S.NO	SYSTEM	TYPE OF MEASUREMENT
6	VENT HEADER OF BOILER (SEPARATOR OUTLET STEAM)	ACC, SP.COND., HYDRAZINE, SILICA
7	MAIN STEAM	pH, ACC, Na, SILICA, SP.COND.,
8	WATER SEPARATION STORAGE TANK OF BOILER	CATION CONDUCTIVITY(ACC)
9	REHEATED STEAM	CATION CONDUCTIVITY(ACC)
10	TG ECW COOLING WATER	pH



# BOILER CONTROL

## **BOILER LOAD CONDITION**

### **Constant Pressure Control**

- ✓ **Above 90% TMCR The MS Pressure remains constant at rated pressure**
- ✓ **The Load is controlled by throttling the steam flow**
- ✓ **Below 30% TMCR the MS Pressure remains constant at minimum Pressure**

### **Sliding Pressure Control**

- ✓ **Boiler Operate at Sliding pressure between 30% and 90% TMCR**
  - ✓ **The Steam Pressure And Flow rate is controlled by the load directly**
-




## Sliding pressure operation

- ▶ Variable pressure operation (sliding pressure operation) is desired in all modern power plants because it provides more efficient part load operation.
- ▶ The loss due to constant pressure operation at low load is always a concern for the utility.
- ▶ The vertical tube supercritical boiler can provide variable turbine pressure operation to gain the thermodynamic advantage of variable pressure.
- ▶ Thus the turbine efficiency advantages are obtained by the savings in boiler feed pump power associated with true variable pressure operation.

## **ADVANTAGES OF SLIDING PRESSURE OPERATION**

- 1. No additional pressure loss between boiler and turbine**
- 2. Low Boiler Pr. at low loads**
  - Less fatigue of Pr. part components**
  - Longer life of all components, Less wear of components**
  - Less Maintenance**
- 3. Lower thermal stresses in the turbine during load changes**
- 4. Overall reduction in power consumption and improved heat rate**

# Sliding Pressure



# Issues and Challenges

- ▶ Erection
- ▶ Commissioning
- ▶ Operation
- ▶ Maintenance Practices

# Replacement of Grade 23 Pipes and Fittings

- Issue of absence of appropriate microstructure following normalizing heat treatment in thick walled Grade 23 pipes and fittings .
- In order to avoid inconvenience during operation in future, It was recommended to replace all Grade 23 pipes and fittings with Grade 91 material
- Headers replaced- SH Division panel outlet ( 2nos), Platen SH outlet, Final SH inlet and their connecting pipes.



# Super critical units -NTPC Experience

Issues related to Welding Joints of T 23 Tubes

# T23 Joints Details

SN	Pressure Part Area	Material	No of Joints	Type of Pressure part
1	Furnace Rear Hanger Tube +Furnace Upper Rear O/L Hdr	T23+T23	136	Tube
2	Furnace Roof I/L Hdr + Furnace Roof Panel	T22+T23	204	Tube
3	Furnace Roof Panel+ Furnace Roof Panel(Loose Tube)	T23+T23	2	Fin Welded
4	Furnace Roof Panel + Furnace Roof Loose Tube	T23+T23	204	Fin Welded
5	Furnace Roof Loose Tube + Furnace Roof O/L Hdr	T23+T23	204	Fin Welded
6	BP Ext Side I/L Hdr + BP Ext Side Panel	T22+T23	108	Tube
7	BP Ext Side Panel + BP Ext Side Floor Panel	T23+T23	108	Fin Welded
8	BP Ext Side Floor Panel + BP Ext Side O/L Term Tubes	T23+T23	108	Fin Welded
9	LTRH Lower Intermediate Assy + LTRH Upper Intermediate Assy	T12+T23	808	Tube
10	LTRH Upper Intermediate Assy + LTRH Upper Assy	T23+T23	808	Tube
11	LTRH Upper Assy + LTRH Pendant Assy	T23+T91	808	Tube
<b>Total</b>			<b>3498</b>	