


All India Wind Penetration (in Energy terms)




→ High Wind generation during June to August.

→ All India level penetration – 9% (max achieved)


→ High Penetration in States:

1. Tamil Nadu
2. Rajasthan
3. Karnataka
4. Gujarat
5. Maharashtra




Balancing Renewable Generation

Flexing the Hydro for Balancing the wind generation in Karnataka



Flexing of Thermal for Balancing Wind Generation in Karnataka





Challenges

- Variability, intermittency and ramping
- Sudden onset or offset of wind generation

Remedies


- Generation balancing by the conventional energy sources.
- Greater the penetration, greater the balancing requirement.
- Forecasting of renewable generation (Solar and wind)
- Ramp forecast is also essential.

Inter-state and Intra-state solar generation scheduling taking place



- **NRLDC**
 - Dadri Solar
 - Unchahar Solar
 - Singrauli Solar
- **Haryana**
- **Rajasthan**
- **Andhra Pradesh**
- **Maharashtra**
- **DVC**

REALTIME GUJARAT SOLAR TREND :- 30/1/2015



Ecosystem for RE Integration...

Existing Ecosystem

- Separate Carriage & Content in Transmission at inter-state level
- Multi-Part Tariff
- Non-Discriminatory Open Access
- Freedom & Choice
- Multi Buyer – Multi Seller
- Robust Imbalance Handling Framework at Inter-state level
- Dispute Free Settlement Systems
- Zonal Transmission Charges & Losses

Further Ecosystem Requirements

- Frequency Control (Primary, Secondary, Tertiary)
- Load Forecasting
- RE Generation Forecasting
- Balancing Resources
- Generation Reserves
- Flexible Generation
- Ancillary Services Market
- Real Time Markets
- Imbalance Handling Framework at Intra-state level in all states

Need for Flexibility

- **CERC IEGC (4th Amendment) (Draft)**
- **Proposed Technical Minimum - 55%**
- **Proposed station heat rate degradation to be considered for the purpose of compensation:**

S.No.	Unit loading as a % of Installed Capacity of the Unit	Increase in SHR (for supercritical units) (%)	Increase in SHR (for sub-critical units) (%)
1	85-100	Nil	Nil
2	75-84.99	1.25	2.25
3	65-74.99	2	4
4	55-64.99	3	6

Forecasting

- **Centralized - Grid Security**
- **De-centralized - Scheduling and Commercial**
- **Forecast Error**
 - Absolute Error
 - Mean Absolute Error
 - Day
 - Week
 - Month
 - Year
 - Percentage Error
 - $\{(\text{Actual Generation} - \text{Scheduled Generation}) / (\text{Available Capacity})\} * 100 (\%)$ to be effective from 01.11.2015

Scheduling

- **Scheduling in Proposed CERC RE Framework**
 - Wind/solar generators at the inter-state level whose scheduling is done by the RLDCs
 - To be paid as per scheduled generation
 - Maximum of 16 revisions for each fixed 1.5 hour time slot
 - Transact through long /medium/short-term trades.
 - Transmission charges (POC charges) and losses applicable
 - Only for Wind at present
 - Exemption to Solar projects commissioned till Jun-2017

Scheduling Enables Electricity Market Access to Renewables

Imbalance Handling and Settlement

- **CERC IEGC, 2010**
 - Mandates action by control areas to control inter-change
 - States revise requisitions / procure power from market
- **Salient Features of Proposed CERC RE Framework**
 - Deviation charges of RE generators delinked from frequency
 - More opportunities to revise the schedule
 - Commercial liability known upfront
 - Centralized as well as De-centralized forecasting
 - No additional charges, surcharges etc.
 - RECs to ensure physical energy balance

Aggregators

- **RE Ownership fragmented, many small investors.**
- **Scope for New Actors / Players**
 - Registered Generation Aggregator (RGA)
 - Qualified Scheduling Entity (QSE)
 - Solar Park developer
- **Need of nodal entity at connection point**
 - Responsible for coordinating with SLDC/RLDC on behalf of all the developers/generators.
- **Need for a separate Institutional Entity**
 - Recognized under regulatory framework
 - Qualified/certified/registered with System Operator
 - Undertake scheduling/commercial settlement/de-pooling/communication/data management and co-ordination etc.
 - Suitable definition may be incorporated in the appropriate regulations including Grid Code.

Metering

- **CERC Proposed Framework**

- Special Energy Meters (SEM) for boundary metering, accounting and settlement.
- Weekly meter readings to the RLDC for energy accounting.

- **CEA Technical Standards for Connection of the Distributed Generation Resources**

- *“4. General Connectivity Conditions - ...(5) The applicant and the user shall coordinate with the appropriate licensee on the issues including but not limited to protection, safety, and metering....”*
- *“8. Metering. - (1) Meters shall be provided as specified in the Central Electricity Authority (Installation and Operation of Meters) Regulations, 2006 for the purpose of metering under these regulations.*
- *(2) Measurement of harmonic current injection, Direct Current injection and flicker shall be done with calibrated meters before the commissioning of the project and once in a year in presence of the parties concerned and the indicative date for the same shall be mentioned in the connection agreement...”*

Other Critical Requirements

- **Data Telemetry**
 - Need for providing data telemetry to the RLDCs by all RE generators
 - Communication infrastructure issues
- **Specification of Technical Characteristics of Solar generators**
 - Need for sharing information with the RLDCs
 - Essential input for facilitating forecasting by the Solar generators as well as the RLDCs

Adherence to Standards (1)

- **CEA Technical Standards for Connection of the Distributed Generation Resources**
 - “...(e) “distributed generation resource” means a generating station feeding electricity into the electricity system at voltage level of below 33 kV;...”
 - “(6) Distributed generation resource operating in parallel with electricity system shall be equipped with the following protective functions.....
 - (a) **over and under voltage trip functions**, if voltage reaches **above 110% or below 80% respectively with a clearing time upto two seconds**; however, appropriate licensee may prescribe a narrower range of voltage for the purpose.
 - (b) **over and under frequency trip functions**, if frequency reaches **50.5 Hz and below 47.5 Hz with a clearing time upto 2 seconds**; however, appropriate licensee may prescribe a narrower range of frequency for the purpose....”


European Experience:

A large amount of PV installed capacity was initially tuned for automatic shedding at 50.2 Hz. A wide retrofitting campaign was performed since 2011 in order to avoid this technical specification, mainly on German and Italian areas. On German area 4 GW of PV installed capacity remains not retrofitted. For Italy the completion of retrofitting will be fulfilled in 2015

Source: Solar Eclipse March 2015: The successful stress test of Europe’s power grid – more ahead ENTSO-E Policy Brief 15 July 2015

Adherence to Standards (2)

- **CEA (Technical Standards for Connectivity to the Grid) Amendment Regulations, 2013**
 - **Power Factor Provisions** - B2(1) *Power factor within the limits of 0.95 lagging to 0.95 leading.”*
 - **FRT / LVRT Provisions** - B2(3) *Fault Ride Through provisions when voltage at the interconnection point on any or all phases dips up to the levels depicted*
 - **Active Power Injection Provisions** - B2(4) *control active power injection in accordance with a set point, based on the directions of the appropriate Load Despatch Centre...”*



Amendments in Connectivity Standards are applicable only to the Wind generating stations and generating stations using inverters
Need for clarity on Connectivity Standards for Solar stations/parks

Installed Pumped Storage Plants

S. No.	Name of Project / State	Installed Capacity		Pumping Mode Operation	Reasons for not working in Pumping mode
		No. of units x MW	Total (MW)		
1	Kadana St. I&II Gujarat	2x60+2x60	240	Not working	Due to vibration problem
2	Nagarjuna Sagar Andhra Pradesh	7x100.80	705.6	Not working	Tail pool dam under construction
3	Kadamparai Tamil Nadu	4x100	400	Working	-
4	Panchet Hill -DVC	1x40	40	Not working	Tail pool dam not constructed
5	Bhira Maharashtra	1x150	150	Working	-
6	Srisaillam LBPH Andhra Pradesh	6x150	900	Working	-
7	Sardar Sarovar Gujarat	6x200	1200	Not working	Tail pool dam not constructed
8	Purlia PSS West Bengal	4x225	900	Working	-
9	Ghatgar Maharashtra	2x125	250	Working	-
		Total	4786		

Way Forward for RE Integration

- Forecasting Load and RE
- Adequacy & Balanced Portfolio
- Framework for integrating RE
- Intra-state deviation handling mechanism in all States
- Aggregators – New market entities
- Reserves
- Ancillary Services
- Frequency Response
- Market opportunities : more frequent clearing
- Communication & data telemetry
- REMCs
- Compliance to Standards
- Flexibility in conventional generation
- Capacity building

References

- www.cercind.gov.in
- www.powermin.nic.in
- www.cea.nic.in
- www.mnre.gov.in
- www.posoco.in
- www.recregistryindia.nic.in
- www.forumofregulators.gov.in
- www.iexindia.com
- www.powerexindia.com



Thank You !!